13th Annual Groundwater Quality Workshop

4040 Paramount Boulevard Lakewood, CA 90712

June 28, 2018 (9:30AM ~ 2:30PM)



Speaker Bio's

WRD's 13th Annual Groundwater Quality Workshop - Speaker Bios

(In order of presentation)

Brian Partington is a senior hydrogeologist at the Water Replenishment District of Southern California. He is responsible for managing a basin-wide groundwater contamination program and is also a lead participant in groundwater sustainability discussions with key stakeholders in the Central Subbasin, Southern Los Angeles County, California. Prior to WRD, Brian managed a large portfolio of environmental investigation / remediation work and was part of a technical practice group responsible for providing technical support for contamination projects nationally and internationally while working for URS/AECOM. He has over 20 years of groundwater experience and received a Bachelor of Science degree in geology from California State University Fullerton. He is also a California Professional Geologist and Certified Hydrogeologist (PG/CHg).

Dmitriy Ginzburg is a senior water resource control engineer at the State Water Resource Control Board, Division of Drinking Water (DDW). He is the Hollywood District Engineer responsible for managing the flow of work and staff engineers in Hollywood District Office and taking actions to issue domestic water supply permits to public water systems under the California Safe Drinking Water Act (SDWA) and issue enforcement actions against public water systems for violations of the SDWA. He responds to media requests for information and interviews concerning drinking water issues. He also oversees and provides technical assistance to Los Angeles County Health Department that has been delegated the responsibility to regulate all public water systems in LA county with less than 200 customers. Dmitriy also actively participates in development of state wide policies and programs. Besides his work in DDW, Dmitriy is an adjunct professor at Los Angeles Trade Technical College teaching water distribution and treatment operator certification courses. Dmitriy has over 15 years of experience in drinking water regulatory oversight and treatment technologies and received his Bachelor of Science degree in chemical and environmental engineering from UCLA. He is also a licensed California Professional Chemical Engineer (P.E.).

Erik Gaiser is a California Professional Geologist with over 20 years' experience in the environmental and water resources fields. He received a Bachelor's of Science degree in Geology from California State University Fullerton and later obtained his state licensing in 2011. While at Yellow Jacket Drilling, he was the business development manager for California and cultivated professional connections with over 2,500 personnel at a variety of organizations including consulting firms, public and private water entities, watermasters and government agencies. He has also served as the lead hydrogeologist and project manager for a multitude of water resource projects and environmental sites ranging from retail petroleum to USEPA Superfund projects. While at ARCADIS, he acted as the West Coast Lead for their High-Resolution Site Characterization Sub-Discipline functioning as a technical resource for projects across the United States. Currently, he serves as the President of the newly formed Inland Empire Branch of the Groundwater Resource Association of California.

Leila Munla is a Process Engineer with GHD. Leila has over 7 years of experience in Membrane Filtration Systems, with a focus on ceramic membrane filtration, fouling mitigation and quantification, and membrane system design and operation. She also has several years of experience as a project engineer designing greywater systems for commercial properties, which include rainwater harvesting systems and tanks. Leila has her PhD in Environmental Engineering from the University of Waterloo in Canada.

WRD's 13th Annual Groundwater Quality Workshop - Speaker Bios

(In order of presentation)

Ryan Kristensen is a civil engineer working with the GHD Water Team in Irvine, CA. Mr. Kristensen has experience in groundwater remediation, stormwater management, recycled water retrofitting, rehabilitation and asset management, and renewable energy design. Ryan has served as a project engineer on feasibility assessments and conceptual studies, facility master plans and capital improvement programs, design management, engineering services during construction, and has helped clients obtain compliance with regulations and permitting requirements. Ryan has a B.S. in Earth and Environmental Engineering from Columbia University and an M.S. in Hydrology and Water Resources Engineering from the UCLA.

Rick Zimmer is the Client Manager at Eurofins Eaton Analytical, LLC, the largest potable water testing laboratory in the United States. Mr. Zimmer holds both Bachelor's and Master's degrees and has over 25 years of experience working in the water industry as a Project Manager, Account Manager, Customer Service Manager and Regulatory Specialist. Mr. Zimmer presently manages projects for Eurofins' customers in California, Hawaii, American Samoa, Guam, the CNMI and Japan. Mr. Zimmer also serves as Safe Drinking Water Committee Chairman for the California-Nevada Section of the AWWA, and Water Quality Committee Member for the Association of California Water Agencies.

Michael Bodart is the President and has been Director of Engineering for General Pump Company for the past 24 years. He is recognized as an expert in the field of pump engineering and well rehabilitation for over 30 years. He has been invited to speak for numerous professional water related associations and conventions. Mike has a Bachelor of Science Degree in civil engineering from the University of Missouri. His post graduate studies included geohydrology from USC and many pump engineering classes. Mike has been speaking professionally for more than 25 years and has presented in nationally known associations such as AWWA, Tri-State, Southern California Water Utility Associations, Inland Water Works Association, Groundwater Resources Association, Southern California Gas Company, Southern California Edison and Central Coast Water Association. Mike teaches courses in water well drilling and rehabilitation. He is responsible for more than 30,000 State approved CEUs. Mike was chosen to be part of a six-person panel who met in Kansas City in 1992 to assist in training nationwide engineers in the water well pump business.

Esther Valle Rojas is a senior water resources planner at the Water Replenishment District of Southern California. She represents the District and acts as the administrator for one of the five Greater Los Angeles County IRWM sub-regions, is responsible for grants management, assists with the administration of the Central Basin and West Coast Basin Watermaster Administrative Body and is the program lead for the new well construction and rehabilitation program. Prior to WRD, Esther served as an analyst and government liaison for the Southern Nevada Water Authority. She has more than ten years' experience in water resources policy and planning and received her Master's degree in City and Regional Planning from California Polytechnic University, San Luis Obispo.



WRD Overview – June 2018

Brian Partington Water Replenishment District bpartington@wrd.org



OF SOUTHERN CALIFORNIA

Overview – June 2018

Brian Partington, PG, CHg June 28, 2018

Program

<u>9:30 - 10:00</u>

WRD Overview Brian Partington, Water Replenishment District of Southern California

<u>10:00 - 10:30</u>

DDW Regulatory Updates Dmitriy Ginzburg, SWRCB – Division of Drinking Water

<u>10:30 - 11:00</u>

Water Well Destruction Standards – County of Los Angeles Department of Public Health Erik Gaiser, Consultant

<u>11:00 – 11:30</u>

Ex-Situ Biological Treatment of Perchlorate Impacted Groundwater Leila Munla and Ryan Kristensen, GHD

<u>11:30 – 12:00</u>

Sampling and Analytical Challenges for Coliforms, Pathogens, Volatiles, 1,4-Dioxane and Nitrosamines Rick Zimmer, Eurofins Eaton Analytical



Program

<u>12:00 – 12:45</u>

Lunch provided by GHD





Program

<u>12:45 – 1:15</u>

Best Way to Address Reoccurring Bacteria Problems in a Water Supply Well Michael Bodart, General Pump Company

<u>1:15 – 1:45</u>

How to Write the Perfect Well Redevelopment Specification Michael Bodart, General Pump Company

<u>1:45 – 2:15</u>

WRD's New Program for Well Rehabilitation and Well Construction Esther Valle Rojas, Water Replenishment District of Southern California

<u>2:15 – 2:30</u>

Questions and Certificates

The presentations will be emailed to the participants and/or uploaded to http://www.wrd.org



High Level Overview of WRD

- History and Mission
- Major Programs
- Resources and Online Programs
- Water Independence Now





Solutions

- WRD formed in 1959 to eliminate overdraft via Managed Aquifer Recharge (MAR).
- Pumping adjudicated at 281,835 acre feet/year (AFY).
- Higher than natural recharge within the basin, but the difference is made up WRD.





GROUNDWATER BASINS IN THE WRD SERVICE AREA



SERVICE AREA = **420 SQUARE MILES**



43 CITIES



POPULATION > 4 MILLION



550,000 ACRE FEET USED PER YEAR



50% GROUNDWATER FROM LOCAL WATER WELLS



50% IMPORTED WATER



WRD SUPPLEMENTS NATURAL GROUNDWATER RECHARGE



SECURING OUR WATER FUTURE TODAY

4040 Paramount Boulevard | Lakewood, California 90712



🍉 @waterreplenish

facebook.com/waterreplenishment youtube.com/waterreplenishment

💮 www.wrd.org

Over 400 Wells Provide Water Supply







HOW WRD MANAGES THE BASINS

REPLENISHMENT OF GROUNDWATER



BASIN MONITORING

GROUNDWATER CLEAN UP



BASIN MODELING





SECURING OUR WATER FUTURE TODAY

4040 Paramount Boulevard | Lakewood, California 90712

@waterreplenish
facebook.com/waterreplenishment
youtube.com/waterreplenishment

www.wrd.org

Replenishment Facilities





LA County Public Works Recharge Facilities









Replenishing Groundwater Basin





Results of WRD Basin Management





Forecasted water levels during drought without recharge





Regional Groundwater Monitoring Program



Nested Monitoring Wells









Data Presented in Two Annual Reports





Reports are available at http://www.wrd.org

Interactive Well Search





Interactive Well Search

WRD Interactive Well Search - Microsoft Internet Explorer p	rovided by WRD	one being brands		
C C C C A A A A A A A A A A A A A A A A	a termina termina analasi	▼ 🗟 47	🗙 🚺 🖸 Bing	• ٩
<u>File Edit View Favorites Tools H</u> elp				
📌 Favorites 🛛 🖶 🖌 🍘 WRD Int 🗴 💽 Windows Li 👔	🎯 Lakers shou 🥥 HP Fax Mac 🌆 Babo	olat Te 🏠 👻 📘	Ŋ ▼ 🖃 🖶 ▼ <u>P</u> ag	ge ▼ <u>S</u> afety ▼ T <u>o</u> ols ▼ 🕡 ▼ [≫]
Signal Interactive Well	Search Woll Reports		NEW	WRD HELP LOGOUT
Constituents.	Total Dissolved Solids (TDS)		CARRY .	
			Print Table	WRD WELL: 100033
Date	Concentration Level	Units		Well Construction
11/19/1998	630	mg/l		Mail Gonstideton
5/12/1999	540	mg/l		
9/22/1999		mg/l		Water Level
5/3/2000		mg/l		
10/10/2000				
5/21/2001	WKD currentiv			Well Production
2/13/2002				
11/4/2002	undating tha			Water Quality
6/23/2003	upualing the			Visiter Classinsy
4/8/2004	· ·		E	
9/9/2004	Intoractive M/oll			52
3/8/2005				Map Scarch
9/13/2005				map sources
8/30/2006	Search Tool	mg/l		New Search
4/11/2007		mg/l		
9/11/2007		mg/l		
4/2/2008		mg/l		
9/2/2008		ma/l		
3/30/2009	394	mg/l		
8/19/2009	360	mg/L		
3/11/2010	370	mg/L		
		and decision of the	· • ·	
100030 4S/13W-09H09S UNK 9H9	CAR1_1 Water Replenishmen	t District Monitoring Well	Active	



Account requests at http://gis.wrd.org/wrdmap/login.asp

Well Profiling Program



Contact Charlene King at cking@wrd.org (562.275.4252)



Safe Drinking Water Program (since1991)

- Financial assistance for wellhead treatment.
- Outreach program for DACs.





Contact Charlene King at cking@wrd.org (562.275.4252)

Groundwater Contamination Program

- WRD staff track the progress of high priority environmental investigations located in the West Coast Basin and Central Basin (currently 46).
- Conduct high level reviews and when necessary provide feedback to the various regulatory agencies including EPA, DTSC, RWQCB.

WRD awarded \$7.28M in Proposition 1 grant funds to cleanup a Perchlorate and VOC "hot spot" in the City of Vernon (March 30, 2017).



Contact Brian Partington at bpartington@wrd.org (562.275.4249)



(WIN) WATER INDEPENDENCE NOW PROGRAM

COLLECTION OF PROJECTS TO ELIMINATE REMAINING DEMAND FOR IMPORTED WATER

A key to developing independence from imported water is the development of local recycled water sources.



WATER INDEPENDENCE NOW

PROJECTS TO:



CAPTURE AND CONSERVE ADDITIONAL STORMWATER



INCREASE USE OF RECYCLED WATER FOR GROUNDWATER REPLENISHMENT

SECURING OUR WATER FUTURE TODAY

4040 Paramount Boulevard | Lakewood, California 90712



🍏 @waterreplenish

💮 www.wrd.org

👔 facebook.com/waterreplenishment



(WIN) WATER INDEPENDENCE NOW PROGRAM

GOAL IS TO REPLACE IMPORTED WATER WITH LOCALLY AVAILABLE WATER (E.G. RECYCLED WATER) FOR AQUIFER REPLENISHMENT.



BENEFITS OF RECYCLED WATER OVER IMPORTED WATER:



INCREASED RELIABILITY

COST-EFFECTIVE



And the state of t

LOCALLY CONTROLLED

DROUGHT PROOF

SECURING OUR WATER FUTURE TODAY

4040 Paramount Boulevard | Lakewood, California 90712

🂓 @waterreplenish

facebook.com/waterreplenishment

💮 www.wrd.org



GROUNDWATER RELIABILITY IMPROVEMENT ADVANCED WATER TREATMENT FACILITY

GRIP IS THE CORNERSTONE OF WRD'S WIN PROGRAM



GROUNDWATER RELIABILITY IMPROVEMENT PROJECT

GRIP WILL PROVIDE 21,000 ACRE-FEET PER YEAR OF RECYCLED WATER IN PLACE OF EXPENSIVE IMPORTED WATER.

UPON COMPLETION, GROUNDWATER BASINS WILL BE COMPLETELY LOCALLY SUSTAINABLE

SECURING OUR WATER FUTURE TODAY

4040 Paramount Boulevard | Lakewood, California 90712

沙 @waterreplenish

facebook.com/waterreplenishment





GROUNDWATER RELIABILITY IMPROVEMENT ADVANCED WATER TREATMENT FACILITY



SECURING OUR WATER FUTURE TODAY

4040 Paramount Boulevard | Lakewood, California 90712

@waterreplenish
 facebook.com/waterreplenishment
 youtube.com/waterreplenishment

www.wrd.org



WATER REPLENISHMENT DISTRICT OF SOUTHERN CALIFORNIA

Thank You!

Brian Partington bpartington@wrd.org

562.275.4249



GROUNDWATER RELIABILITY IMPROVEMENT PROJECT



WATER INDEPENDENCE NOW



DDW Regulatory Update

Dmitriy Ginzburg SWRCB - DDW

Dmitriy.Ginzburg @waterboards.ca.gov

DIVISION OF DRINKING WATER REGULATORY UPDATES



2018 ANNUAL GROUNDWATER QUALITY WORKSHOP

JUNE 28, 2018

DMITRIY GINZBURG, P.E., HOLLYWOOD DISTRICT



DIVISION OF DRINKING WATER (DDW)

STATE WATER RESOURCES COMPROL BOARD

DDW REGULATORY UPDATES

DDW reg update 6/28/2018

- LEAD SAMPLING IN SCHOOLS
- LEAD SERVICE LINE INVENTORY
- 1,2,3 TCP MCL
- 2018 REGULATORY PRIORITIES



LEAD SAMPLING IN SCHOOLS 2017 PERMIT AMENDMENT & 2018 ASSEMBLY BILL 746

- PERMIT AMENDMENT ISSUED IN JANUARY 2017 ANY K-12 SCHOOL (PUBLIC & PRIVATE) IN CALIFORNIA CAN REQUEST SAMPLING FOR LEAD
 - OPTIONAL PROGRAM FOR BOTH PUBLIC AND PRIVATE SCHOOLS
- ASSEMBLY BILL 746 WENT INTO EFFECT JANUARY 2018, REQUIRES ALL COMMUNITY WATER SYSTEMS TO TEST PUBLIC K-12 SCHOOLS FOR LEAD
 - MANDATORY PROGRAM FOR PUBLIC SCHOOLS


TESTING RESULTS (BOTH PERMIT AMENDMENT AND AB746)

AS OF APRIL 22, 2018:

- RESULTS HAVE BEEN RECEIVED FOR 12,986 SAMPLES
- ACTION LEVEL = 15 PPB OR 15 MICROGRAMS/LITER
- LEAD HAS BEEN DETECTED BETWEEN 0 (PARTS PER BILLION) PPB AND 15 PPB IN > 99% OF ALL SAMPLES
- 90 SAMPLE LOCATIONS AT 81 SCHOOLS HAD ONE OR MORE RESULT
 >15 PPB (<1% OF SAMPLE LOCATIONS)







ACTION LEVEL EXCEEDANCES: WHAT ARE SCHOOLS DOING?

90 LOCATIONS W/ ACTION LEVEL EXCEEDANCES (<1%)

(AS OF APRIL 22, 2018)

- EXAMPLES OF FOLLOW-UP ACTIONS
 - REPLACED FIXTURE
 - COLLECTED MORE SAMPLES/NO FURTHER ACTION
 - REMOVED FROM SERVICE
 - MORE SAMPLES/INVESTIGATION/REPLACED BUBBLER PLUS
 PART OF LINE
 - ADDED POINT-OF-USE FILTER



LEAD SAMPLING OF DW IN CA SCHOOLS AB 746

- AB 746 WAS SIGNED ON OCTOBER 13, 2017
- ADDED SECTION 116277 TO H&S CODE (1/1/2018)
- SIMILAR REQUIREMENTS TO DDW PERMIT
- REQUIRES CWS TO SAMPLE ALL "LOCAL EDUCATIONAL AGENCIES" DEFINED AS SCHOOL DISTRICT, COUNTY OFFICE OF EDUCATION, PRE SCHOOL, OR CHARTER SCHOOL LOCATED IN A PUBLIC FACILITY



LEAD SAMPLING OF DW IN CA SCHOOLS AB 746

- SAMPLING GUIDANCE FROM DDW WILL BE THE SAME AS DDW PERMIT
- LEAD TESTING EXEMPT FOR:
 - SCHOOLS THAT WERE CONSTRUCTED OR MODERNIZED AFTER JULY 1, 2010 (REPLACED OF ALL WATER PIPING AND FIXTURES)
 - SCHOOLS THAT ARE CURRENTLY PERMITTED AS PUBLIC WATER SYSTEMS AND ARE CURRENTLY REQUIRED TO TEST FOR LEAD IN THE POTABLE WATER SYSTEM.
 - SCHOOLS THAT HAVE INDEPENDENTLY COMPLETED LEAD TESTING OF THEIR POTABLE WATER SYSTEM AFTER JANUARY 1, 2009 AND HAVE POSTED ALL INFORMATION ABOUT THE TESTING ON THEIR PUBLIC INTERNET WEB SITE
 - SCHOOLS THAT HAVE REQUESTED LEAD TESTING UNDER THE 2017 PUBLIC WATER SUPPLY PERMIT AMENDMENT
- EXEMPTION FORM POSTED TO DDW WEBSITE



LEAD IN SCHOOLS - AB 746 VS. PERMIT AMENDMENTS

Requirements	AB 746 (CHSC §116277)	Lead In Schools Permit Amendment (Jan. 2017)	
Audience	<u>Community Water Systems (CWS) serving a</u> <u>schoolsite of a local education agency (LEA*)</u> w/ building constructed before 1/1/2010. (Includes K-12, preschools and child daycare located on public school property)	Public Water System serving K-12 school for which sampling request is made prior to 11/1/2019	
Number of Initial Samples	N/A (DDW will continue to reference DDW posted guidance and 3Ts to CWS/LEAs)	One to five samples from regularly used sinks, faucets, fill stations	
Sampling Time	Anytime, but must be completed before 7/1/2019 (DDW guidance prescribes sampling while school is in session and not immediately following weekends or holidays)	During school year, on Tues/Wed/Thurs/Fri. when in session and in session for one day prior. (Within 90 days after receiving request)	
PWS Reporting to School	Report findings to schoolsite within 10 business days after receiving results from lab	Provide/discuss sample results with school within 10 days of receiving results from lab	
PWS Reporting to State	N/A (DDW will need the submittal of data to LIS website to determine compliance)	 Compile list of names/addresses K-12 by 7/1/2017, submit to DDW's LIS website Require lab to submit data to DDW's LIS website 	
	0		

DDW reg update 6/28/2018

LEAD IN SCHOOLS - AB 746 VS. PERMIT AMENDMENTS

Requirements	AB 746 (CHSC §116277)	Lead In Schools Permit Amendment (Jan. 2017)		
Action Level (AL)	1 <i>5</i> ppb	1 <i>5</i> ppb		
AL Exceedance Response by PWS	 Report to school within 2 business days <u>Collect repeat sample at the service</u> <u>connection between CWS and schoolsite</u> 	 Notify school within 2 school business days Collect resample within 10 business days if sample site remains in service Collect third sample within 10 business days after notification that resample is ≤ 15ppb Following corrective action, collect resample 		
AL Response by LEAs	 Notify parents and guardians of pupils where elevated levels found Take immediate steps to make fountains/faucets inoperable (shut down) where levels above AL found Additional testing (may be?) required to determine if all or just some of fountains/faucets require shut down (Enforced by DDW & CDE; DDW will continue tracking) 	N/A – School corrective actions not enforceable by DDW.		

LEAD IN SCHOOLS - AB 746 VS. PERMIT AMENDMENTS

Requirements	AB 746 (CHSC §116277)	Lead In Schools Permit Amendment (Jan. 2017)	
Sampling Plan	CWS, in cooperation with LEA, shall prepare a sampling plan for each schoolsite where sampling is required. CWS/LEA may request assistance from State Board or Local Health Dept.	Respond in writing within 60 days of receiving the school's sampling request, and schedule meeting with school to develop sampling plan (3Ts referenced). Finalize within 90 days of request.	
Laboratory Cert.	N/A (DDW guidance prescribes USEPA's 3Ts and ELAP- certified laboratories)	ELAP Certified	
PWS Data Disclosure	N/A	Not release data to public for 60 days following receipt of initial results unless complying with PRA. Discuss results with school prior to release.	

DDW reg update 6/28/2018

DDW CONTACTS FOR LEAD SAMPLING IN SCHOOLS

- DDW STAFF AVAILABLE TO ASSIST SCHOOLS AND WATER SYSTEMS. PLEASE USE CONTACT INFO BELOW
 - BETI GIRMA: (916) 322-9602 OR
 - ARIEL CHAVEZ: (916) 322-9601
 - DDW-PLU@WATERBOARDS.CA.GOV
- MORE INFO ON WEBPAGE:

HTTPS://WWW.WATERBOARDS.CA.GOV/DRINKING WATER/C ERTLIC/DRINKINGWATER/LEADSAMPLINGINSCHOOLS.HTML



LEAD USER SERVICE LINES IN PUBLIC WATER SYSTEMS

SECTION 116885 OF THE CALIFORNIA HEALTH AND SAFETY CODE

REQUIRES ALL PUBLIC WATER SYSTEMS (PWS) TO COMPILE AN INVENTORY OF KNOWN PARTIAL OR TOTAL LEAD USER SERVICE LINES IN USE IN ITS DISTRIBUTION SYSTEM. THE INVENTORY MUST INCLUDE ALL USER SERVICE LINES THAT ARE ACTIVE AND THOSE THAT ARE REASONABLY EXPECTED TO BECOME ACTIVE IN THE FUTURE.

SECTION 116885 ALSO REQUIRES THE PWS IDENTIFY AREAS THAT <u>MAY</u> HAVE LEAD USER SERVICE LINES IN USE, AND/OR IDENTIFY <u>ANY AREAS</u> WITHIN THE PWS DISTRIBUTION SYSTEM THAT THE PWS CANNOT IDENTIFY THE MATERIAL THAT IS BEING USED FOR THE SERVICE LINE.



LEAD USER SERVICE LINES REQUIREMENTS

- INVENTORY MUST BE COMPLETED BY JULY 1, 2018
- THE LSL INVENTORY SUBMITTED VIA THE ELECTRONIC ANNUAL REPORT. EAR IS DUE JUNE 1 AND CAN BE SUBMITTED WITHOUT THE LSL INFORMATION. IF SUBMITTING WITHOUT LSL INFO, YOU MUST ASK YOUR DISTRICT OFFICE TO SEND IT BACK TO YOU PRIOR TO JULY 1 AND RESUBMIT.
- LEGISLATION IS ONLY CONCERNED ABOUT LEAD LINES AND UNKNOWN MATERIAL, ALL OTHER IDENTIFIED MATERIAL (COPPER, GALVANIZED, POLY, ETC.), ARE ACCEPTABLE.
- PWS WILL BE REQUIRED TO PROPOSE A SCHEDULE TO REPLACE ALL THE KNOWN LEAD USER SERVICE LINES AND USER SERVICE LINES CONSTRUCTED OF UNKNOWN MATERIAL.
- **BY JULY 1, 2020,** THE PROPOSED SCHEDULE OR TIMELINE IS REQUIRED TO BE SUBMITTED TO DDW AND THEN POSTED ON OUR WEBSITE.
- FOR MORE CLARIFICATION, WATER SYSTEMS SHOULD DIRECT QUESTIONS TO THEIR RESPECTIVE SWRCB DISTRICT OFFICE



DDW LEAD USER SERVICE LINES REQUIREMENTS WEBSITE



Drinking Water Water Quality

Water Rights

Notices

Water Boards Search

DDW reg update 6/28/2018

Home Drinking Water Certlic Drinkingwater Lead Service Line Inventory Pws

Board

Programs

Lead Service Line Inventory Requirement for Public Water Systems

Background

Existing laws require public water systems (PWS) to take specified actions to test for and remediate certain contaminants in drinking water, including lead and copper. Existing law prohibits the use of any pipe, pipe or plumbing fitting or fixture, solder, or flux that is not "lead free" in the installation or repair of any public water system or any plumbing in a facility providing water for human consumption, except as specified. Section 116885 of the California Health and Safety Code, Lead Service Lines in Public Water Systems, added to the Health and Safety Code by Senate Bill 1398 (2016) and amended by Senate Bill 427 (2017), requires all community water systems (CWS) to compile an inventory of known partial or total lead user service lines in use in its distribution system by July 1, 2018. The inventory must include all user service lines that are active and those that are reasonably expected to become active in the future. Also, Section 116885 requires that CWS identify areas that may have lead user service lines in use, and/or identify any areas within the CWS distribution system that the CWS cannot identify the material that is being used for the service line. CWS will be required to propose a schedule to replace all the known lead user service lines and user service lines constructed of unknown material by July 1, 2020. "User service line" means the pipe, tubing, and fittings connecting a water main to an individual water meter or service connection.

HSC Section 116885 requires CWS, after completing the inventory, to provide a timeline for replacement of known lead user service lines in the distribution system to the State Water Resources Control Board (State Board) by July 1, 2020. In addition, by July 1, 2020, CWS with areas that may have lead user service lines in use in its distribution system must either determine the existence or absence of lead user service lines in these areas and provide that information to the State Board, or provide a timeline for replacement of the user service lines whose content cannot be determined. The State Board must approve the replacement timeline..

For more information, please see our Frequently Asked Questions (FAQ) document (link below).

For more information, click on the links below.

• Senate Bill 1398

• Senate Bill 427

What is My Community Water System Required to do?

HSC Section 116885 requires all CWS to compile an inventory of known partial or total lead user service lines in use in its distribution system. The inventory must include all user service lines that are active and those that are reasonably expected to become active in the future. Also, Section 116885 requires the CWS identify areas that may have lead user service lines in use, and/or identify any areas within the CWS distribution system that the CWS cannot identify the material that is being used for the service line. CWS will be required to propose a schedule to

https://www.waterboards.ca.gov/drinking water/certlic/drinkingwater/lead service line inventory pws.html

15

1,2,3-TCP: MCL & Public Health Goal 1. THE MAXIMUM CONTAMINANT LEVEL (MCL) FOR THIS SYNTHETIC ORGANIC CHEMICAL (SOC) IS 0.000005 MG/L (PPM)

- 2. MCL = 5 PARTS PER TRILLION (PPT)
- 3. THE PUBLIC HEALTH GOAL (PHG) OF 0.7 PPT WAS ESTABLISHED IN 2009 BASED ON CARCINOGENIC EFFECTS
- 4. THERE IS NO FEDERAL MCL FOR 1,2,3-TCP

1 ppm = 1 cup of water in a swimming pool
1 ppb = 1 mL (less than one teaspoon) of water in an Olympic sized swimming pool
1 ppt = Less than half of a drop of oil in a super tanker containing six million gallons of oil.

) 16

DDW reg update 6/28/2018

CA 1,2,3-TCP REGULATIONS

1,2,3-Trichloropropane at a Glance				
Analyte Group	Synthetic Organic Chemical			
Public Health Goal	0.7 ppt			
Detection Level for Purposes of Reporting	5 ppt			
Maximum Contaminant Level	5 ppt			
Best Available Technology	Granular Activated Carbon			
Effective Date of New Regulations	December 14, 2017			
Initial Sampling Start Date	Quarterly beginning January 2018			
Public Water Systems Required to Monitor	Community and Nontransient-Noncommunity			
217	DDW reg update 6/28/2018			

1,2,3-TCP MCL COMPLIANCE

• COMPLIANCE

- BASED ON RUNNING ANNUAL AVERAGE (RAA)
- MAY BE OUT OF COMPLIANCE BEFORE COLLECTING 4 QUARTERLY SAMPLES (E.G., 35 PPT SAMPLE)

MONITORING

- INITIAL QUARTERLY MONITORING FOR 1 YEAR STARTED JANUARY 2018
- IF 1,2,3-TCP IS DETECTED AT OR ABOVE THE MCL -

FOR **SMALLER SYSTEMS (< = 3,300 POPULATION)**

- QUARTERLY FOLLOW-UP SAMPLES FOR ONE YEAR
- COMPLIANCE IS BASED ON THE RUNNING ANNUAL AVERAGE (RAA)

DDW reg update 6/28/2018



1,2,3-TCP MCL COMPLIANCE

FOR LARGER SYSTEMS (> 3,300 POPULATION)

- COMPLIANCE IS BASED ON THE AVERAGE OF THE INITIAL, CONFIRMATION SAMPLE(S), AND SIX MONTHLY SAMPLES.
- IF THE AVERAGE IS LESS THAN THE MCL:
 - SWITCH TO QUARTERLY MONITORING
 - DETERMINE COMPLIANCE BASED ON THE RUNNING ANNUAL AVERAGE

 A SINGLE RELATIVELY HIGH SAMPLE RESULT CAN CAUSE THE RAA TO EXCEED THE MCL FOR THE WHOLE YEAR (EVEN IF THE YEAR IS NOT YET COMPLETE)
 CONSISTENT WITH EXISTING REGULATIONS FOR SYNTHETIC ORGANIC CHEMICALS

DDW reg update 6/28/2018



Compliance Determinations – Example 1

ANY size system with No detections					
Month	Compliance Period	Result	Average for Quarter	Average for FULL Year	
February	1 st Quarter	ND = 0	0	0	
Мау	2 nd Quarter	ND = 0	0	0	
August	3 rd Quarter	ND = 0	0	0	
November	4 th Quarter	ND = 0	0	0	
✓ Initial Sampling Requirements are met!					

20

Compliance Determinations – Example 2

Larger system (> 3,300 people) with a Low Detection in 1 st Quarter				
Month	Compliance Period	Result	RAA of seven samples	
February	1 st Quarter	7		
March	Monthly	9		
April	Monthly	5		
Мау	Monthly	ND (0)		
June	Monthly	6		
July	Monthly	9		
August	Monthly	ND (0)	5.1 (Average for 7 months)	
 ✓ System is in compliance through August for the year. 				
 System IVIUST collect another quarterly sample in November. 				

Compliance Determinations – Example 3

Month Compliance Period R	Result	RAA of ALL 7 samples		
	10			
February 1 st Quarter	12			
March Monthly	9			
April Monthly	21	6 ppt (MCL has been exceeded – even if the rest of the results are Non-detect)		
May Monthly	ND			
June Monthly	ND			
July Monthly	ND			
August Monthly	ND	6 =(Average for 7 months)		
Source exceeds the MCL based on the April result				

1,2,3-TCP Compliance Options

OPTIONS FOR A WELL THAT IS OUT OF COMPLIANCE:

- PROVIDE TREATMENT (GAC OR OTHER DISTRICT-APPROVED TREATMENT)
- DRILL NEW WELL
- REMOVE THE WELL FROM USE



DDW reg update 6/28/2018

- PURCHASE WATER FROM A NEARBY UTILITY
- CONSOLIDATE WITH A NEARBY LARGER WATER
 SYSTEM

23



OPERATIONS AND CARBON LIFE

- GAC IS A PROVEN TREATMENT TECHNOLOGY FOR ORGANIC
 CONTAMINANTS
- CARBON LIFE CAN VARY DEPENDING ON CARBON TYPE AND SOURCE WATER
- PWS SHOULD PILOT TEST THE PROPOSED CANDIDATE GAC MEDIA TO ESTIMATE TREATMENT CAPACITY
- NSF/ANSI 61 CERTIFIED VIRGIN GAC SHOULD BE USED TO MINIMIZE DELAY IN PERMIT REVIEW

DDW reg update 6/28/2018





DDW 1,2,3-TCP WEBSITE ∧ f ¥ & ⊠ About Us Contact Us Subscribe ♦ Settings

Water Quality

Water Rights

Notices

Water Boards

Search

DDW reg update 5/9/2018

Drinking Water



Home Drinking Water Certlic Drinkingwater 123TCP

1,2,3,-Trichloropropane (1,2,3 - TCP)

Æ

Board

Programs

Announcements

- 1,2,3-Trichloropropane Utility Training Webcast
- * 1,2,3-Trichloropropane Utility Training Presentation Slides
- * SBDDW-17-001 1,2,3-Trichloropropane MCL Effective December 14, 2017
- 1,2,3-Trichloropropane Utility Notification for CWS/NTNC
- Template for Public Notification for 1,2,3-TCP MCL Exceedance is now available

Background

1,2,3- TCP is a chlorinated hydrocarbon with high chemical stability. It is a manmade chemical found at industrial or hazardous waste sites. It has been used as a cleaning and degreasing solvent and also is associated with pesticide products.

1,2,3-TCP causes cancer in laboratory animals (US EPA, 2009). It is reasonably anticipated to be a human carcinogen (NTP, 2014), and probably carcinogenic to humans, based on sufficient evidence of carcinogenicity in experimental animals (IARC, 1995). In 1992, 1,2,3-TCP was added to the list of chemicals known to the state to cause cancer, pursuant to California's Safe Drinking Water and Toxic Enforcement Act (Proposition 65)..

In 1999, we established a 0.005-micrograms per liter (µg/L) drinking water notification level for 1,2,3-trichloropropane (1,2,3-TCP). This value is based on cancer risks derived from laboratory animals studies (US EPA, 1997). The notification level is at the same concentration as the analytical reporting limit, as described below. Certain requirements and recommendations apply if 1,2,3-TCP is detected above its notification level.

26

https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/123TCP.html

DDW REGULATORY PRIORITIES FOR 2018

- ECONOMIC FEASIBILITY CRITERIA
- 2. HEXAVALENT CHROMIUM MCL
- 3. LEAD AND COPPER RULE REVISIONS (LCR)
- 4. SURFACE WATER AUGMENTATION (SWA) REGULATION
- 5. DIRECT POTABLE RE-USE (DPR) RESEARCH AND FRAMEWORK
- 6. REVISED TOTAL COLIFORM RULE (RTCR)
- 7. CROSS-CONNECTION CONTROL REGULATIONS
- 8. ENVIRONMENTAL LABORATORY ACCREDITATION PROGRAM (ELAP) REGULATIONS
- 9. PRIMACY PACKAGE APPLICATIONS
- 10. DIRECT POTABLE RE-USE REGULATIONS
- 11. REVISED DETECTION LIMIT FOR PURPOSES OF REPORTING FOR PERCHLORATE

DDW reg update 5/9/20

QUESTIONS/COMMENTS?

DMITRIY.GINZBURG@WATERBOARDS.CA.GOV

(818) 551-2022

HTTPS://WWW.WATERBOARDS.CA.GOV/DRINKING WATER/PROGRAMS/INDEX.HTML





Well Destruction: The Standards (And a few Oddities)

Erik Gaiser

Consultant

Well Destruction: The Standards (And a Few Oddities)



2018 Annual Groundwater Quality Workshop

Presented by: Erik Gaiser, CA PG 8879

Well...What are the Standards?

California Department of Water Resources Bulletin 74-81 Bulletin 74-90



 California Well Standards California Department of Water Resources. June 1991

http://wdl.water.ca.gov/groundwater/wells/california well standards/well standards content.cfm

Erik Gaiser, CA PG 8879

To Maintain or Destroy...That is the Question

Chapter II. Part III. Section 21.

A well is considered 'abandoned' or permanently inactive if <u>it has not been used for</u> <u>one year, unless the owner demonstrates intention to use the well again.</u> In accordance with Section 115700 of the California Health and Safety Code, the well owner shall properly maintain an inactive well as evidence of intention for future use in such a way as the following requirements are met:

- The well shall not allow impairment of the quality of water within the well and groundwater encountered by the well
- 2) The top of the well/well casing shall be provided with a cover, that is secured by a lock or by other means to prevent its removal without the use of tools, to prevent unauthorized access, to prevent a safety hazard to humans and animals, and to prevent illegal disposal of wasters into the well
- The well shall be marked and labeled so as to be easily visible and identified
 The area around the well shall be kept clear of brush, debris, and waste materials

Chapter II. Part III. Section 22.

All 'abandoned' wells and exploration or test holes shall be destroyed.

Erik Gaiser, CA PG 8879



So You've Decided to Destroy

First comes Condition, Construction, and Obstructions Chapter II. Part III. Section 23.

Before a well can be destroyed, it shall be investigated to determine its:

Condition

1



So You've Decided to Destroy

First comes Condition, Construction, and Obstructions Chapter II. Part III. Section 23.

Before a well can be destroyed, it shall be investigated to determine its:

Condition
 Details of its construction, and



"The free / File Origi Page <u>1</u> Owner's 1 Date Wor Local Per Permit N	te free Adobe Reader may be used to view and complete this form. However, software must be punchased to a Original with DWR State of California ge 1 of 1 Well Completion Report Alter to Mathematical States of California Well Completion Report Alter to Mathematical States of California No. 332123 to Work Bridge Original States of California No. 332123 No. 332124		st be purchased to com ornia on Report Computer	plete, save, and reuse a save DWR Use State Well Lashuda	d form. Orly – Do Not Fill In Number/Sile Number Longhuse	
Geologic Log Orientation O Vertical O Horizontal O Angle Specify Driting Method Direct Rotary Driting Fuld Mud Depth from Surface Description Even Description			Well Owner Name_Carlos Santana Mailing Address_123 Water Drive City_Palm Springs State CA zip_95476			
0 90 160 175 180	90 160 175 180 220	Brown sand & gravel with streaks of sand blue clay wistreaks of sand brown clay and sand brown sand and gravel brown clay with streaks of sand	d	Address <u>123 A'</u> City <u>Los Angel</u> Latitude <u></u> Datum APN Book <u>123</u> Township <u>0</u>	Well Locati VE A 85 0	on County Los Angeles IlludeWDec. LongWParcel 03Section 0
					North	O Modification/Repair O Deepen

Downhole Cameras



Erik Gaiser, CA PG 8879

So You've Decided to Destroy

First comes Condition, Construction, and Obstructions Chapter II. Part III. Section 23.

Before a well can be destroyed, it shall be investigated to determine its:

- 1. Condition
- 2. Details of its construction, and

 Whether there are obstructions that will interfere with the process of filling and sealing





Erik Gaiser, CA PG 8879

Ready to Destroy...What are the Options? **Two Basic Methods:** Seal

Overdrill



Erik Gaiser, CA PG 8879

Or

Suitable Sealing/Filler Materials

September 2015 Statewide Advisory on Sealing Materials

Task Force findings indicate that <u>bentonite slurries do not perform adequately as a</u> <u>sealing material in the unsaturated zone.</u> Bentonite slurries can shrink and crack when they dry out, and they do not adequately hydrate and swell once water is <u>reintroduced to the seal. (http://wdl.water.ca.gov/groundwater/wells/standards.cfm)</u>

So What Does Work?

Part II. Section 9. D.

- <u>Neat Cement</u> Type I or II Portland cement mixed at a ratio of one 94-pound sack of cement to 5 to 6 gallons of 'clean' water
- <u>Sand-Cement</u> Type I or II Portland cement mixed at a ratio of one 94-pound sack of cement to 188 pounds of sand and ~7 gallons of 'clean' water (10.3 sack mix)
- 3) <u>Concrete</u> At least six-94 pound sacks of Portland cement per yard³ of aggregate
- 4) <u>High Solids Bentonite Grout</u> Sand-to-Bentonite ratio of 4:1 to 8:1 by dry weight, and a solids content (i.e. sand and soduim bentonite) between 64%-72% by dry weight to the total weight of the mixed grout

Suitable Sealing/Filler Materials

Additives

- 1) <u>Hydrated Lime</u> Up to 10% of the volume of cement
 - Benefit increases the plasticity/fluidity of the sand-cement mixture and reduces shrinkage cracking
- 2) <u>Bentonite</u> Up to 6% by weight of cement
 - Benefit reduces heat generated during the curing process
- <u>Accelerants</u> Must meet ASTM C494, Standard Specification for Chemical Admixtures for concrete, and latest revision thereof
 - Benefit reduces curing time (CAUTION increases the heat generated during the curing process)

Filler Materials

Crushed Stone, Gravel, and Sand are the most commonly used
 Silt, Clay, and Native Soils can be used but are uncommon due to the additional care that must be used during emplacement
Well in Unconsolidated Material and Unconfined Groundwater Part III. Chapter II. Section 23. B. 1.

1) Sealing material in upper 20 feet

2) Fill or Sealing material in remainder



Well Penetrating Several Aquifers or Formations Part III. Chapter II. Section 23. B. 2.

.) Sealing material in upper 20 feet

2) Where interchange between zones is in <u>no way detrimental</u>, suitable fill or sealing material may be placed opposite the formations penetrated



Well Penetrating Several Aquifers or Formations (Deleterious Water) Part III. Chapter II. Section 23. B. 2.

1) Sealing material in upper 20 feet

2) Where interchange between zones will result <u>in a significant</u> <u>deterioration</u> of water quality in one or more aquifers, the formation(s) producing the deleterious water <u>shall be sealed by</u> <u>placing impervious material</u> <u>opposite the formation , and</u> <u>opposite the confining layers above</u> <u>and below for no less than 10 feet</u>

) Fill/Sealing material can be placed in the remainder



Well Penetrating Several Aquifers or Formations (Artesian) Part III. Chapter II. Section 23. B. 2.

.) Sealing material in upper 20 feet

- 2) Where interchange between zones will result <u>in a loss of artesian</u> <u>pressure</u>, the formation(s) causing the pressure loss <u>shall be sealed by</u> <u>placing impervious material</u> <u>opposite the formation , and</u> <u>opposite the confining layers above</u> <u>and below for no less than 10 feet</u>
- Fill/Sealing material can be placed in the remainder



Sealing Scenarios – Pop Quiz

Well with Unknowns Part III. Chapter II. Section 23. C. 5-7.

.) Perforate the entire length of casing

- Place sealing material within the casing <u>under pressure</u> so that it is forced out into any gravel pack, filling it, and out into the formation
- Pressure must be maintained for a length of time sufficient for the cementing mixture to set



Additional Requirements for Wells in Urban Areas Part III. Chapter II. Section 23. E.

- A hole shall be excavated around the well casing to a depth of 5 feet and the casing removed to the bottom of the excavation
- 2) The sealing material used for the upper portion shall be allowed to spill over into the excavation to form a cap
- 3) After sealing material has set, the excavation shall be filled with native soil



And Now a Few Oddities What do you do when your well looks like this?



Erik Gaiser, CA PG 8879

And Now a Few Oddities ... Or this?



And Now a Few Oddities What about this?



Erik Gaiser, CA PG 8879





Ex-Situ Biological Treatment of Perchlorate Impacted Groundwater

Leila Munla GHD leila.munla@ghd.com Ryan Kristensen GHD

ryan.kristensen@ghd.com



Ex-Situ Biological Treatment of Perchlorate Impacted Groundwater

Leila Munla, PhD| Process Engineer Ryan Kristensen, PE| Civil Engineer

WRD Annual Groundwater Quality Workshop June 28th, 2018





Perchlorate Sources in Groundwater

<u>Sources</u>

- Anthropogenic
- Natural

Properties

- Highly soluble
- Very stable
- Very mobile
- Difficult to detect
- Difficult to treat





Perchlorate Regulatory Update

Health Effects of Perchlorate

Maximum Contaminant Level

• 6 ug/L in 2007

Public Health Goal (PHG)

• 1 ug/L in 2015

Arizonians' Thyroid Problems May Be Linked To Perchlorate In Drinking Water



Perchlorate contamination of drinking water may be the source of thyroid problems among Arizona residents.

Arizona has more perchlorate contamination than most other states, according to KAWC. The Colorado River is contaminated with the chemical because it moves from an industrial facility in Henderson, NV, to groundwater to Lake Mead, which feeds the river.



"Northern Arizona University researchers have

received a 200-thousand-dollar grant from the Flinn Foundation to study the contaminant's effects on the Yuma population," KAWC reported. Yuma County is in southwestern Arizona.

Detection Limit for purposes of Reporting (DLR)

- 4 ug/L
- Under review as per Resolution 2017-0041



Ion Exchange – Process Description

 $\mathsf{R}_4\mathsf{N}^+\mathsf{C}\mathsf{I}^- + \mathsf{C}\mathsf{I}\mathsf{O}_4^- \Leftrightarrow \mathsf{R}_4\mathsf{N}^+\mathsf{C}\mathsf{I}\mathsf{O}_4^- + \mathsf{C}\mathsf{I}^-$

- Reversible chemical reaction
 - Exchange perchlorate for chloride
 - Can be affected by competing ions





Biological Processes

$ClO_4^- + CH_3COO^- \rightarrow Cl^- + 2HCO_3^- + H^+$

Process Description

- Electron Acceptor
 - Order (DO, Nitrate, perchlorate, Sulfate)
- Carbon "Food" Source Electron Donor
 - Acetate (Acetic Acid)
 - Ethanol
- Nutrient Dosing
 - Phosphoric Acid





Fluidized Bed Reactor – Process Description

Technology

- Solid media: sand or GAC
- Specific density decreases as biomass grows
- High surface area





Fluidized Bed Reactor

- Pros
 - Consistent operating cost at various concentrations
 - Effective for high perchlorate concentrations
- Cons
 - High maintenance
 - Long start up time
 - Very sensitive to operating conditions





Microvi – Process Description

- Technology
 - Biocatalyst composite emulates soil conditions
 - Self-contained no loss or overgrowth
 - 5-10 mm structure porous and squishy
- Startup
 - 1-2 days
 - 1 hour after short maintenance
- Operation
 - No backwash required
 - Importance of appropriate dosing online nitrate monitoring
 - Replacement cost of media 10-15% of capital cost
 - Contact time depends on water quality goals
 - Maintenance Clean tank once/1-2 weeks











Microvi

- Pros
 - Quick startup times
 - Low operating costs
 - No sludge production
 - Low maintenance
- Cons
 - Post-filtration step required (for potable)
 - Hydraulics break in head





Continuously Stirred Tank Reactor – Process Description





GHD

Perchlorate Removal Technologies

Ion Exchange

- Concentrates perchlorate
 - Difficult waste product
- High removals
- Maintains hydraulics
- Competing ions
- Lower capital cost
- Higher operating costs at higher concentrations

Biological

- Transforms perchlorate into chloride
- Sludge waste produced
- May require post filtration or polishing step
- Online monitoring
- Must fully remove nitrate first
- Breaks head
- Higher capital costs than IX
- Consistent operating costs
- HRT based on influent concentration
- Potential H₂S production



CASE STUDIES

West Valley Water District - FBR



Source Water

- 2000 gpm (3 GW Wells)
- Up to 1000 ppb CIO₄⁻
- 5.6 mg/L NO₃-N
- 9 mg/L DO

Turbulence Tank

Reduce DO to prevent agitation of the FBR biofilm

Fluidization Pumps and Chemical Dosing

- Electron Donor: Acetic Acid
- Nutrient Solution: Phosphoric Acid

Fluidized Bed Reactor

- GAC and Indigenous Microbial Population
- Influent Turbidity: 0.5 NTU
- Effluent Turbidity: 1-18 NTU

Clarification and Filtration

- Aluminum Chlorohydrate (ACH) Coagulant
- Skid Treatment using <u>Trident Clarifier</u>

Dissolved Air Floatation

Magnafloc E38 Polymer added prior to DAF

Disinfection

Chlorination following Clearwell to allow for Recycling

Finished Water

- ND CIO₄⁻
- ND NO₃-
- 0.02-0.1 NTU

WVWD Clarification and Filtration

Trident[®] HS Package Water Treatment Plant





WVWD SCADA



GHD

WVWD Real Time Monitoring (Dionex)



GHD

Whittaker-Bermite Perchlorate Treatment System

Source Water

- 200 gpm (4 GW Wells)
- Up to 4000 ppb ClO₄-
- VOCs (TCE and PCE)

VOC Treatment

GAC to remove VOCs prior to FBR

Perchlorate Treatment

Fluidized Bed Reactor

Fluidization Pumps and Chemical Dosing

- Electron Donor: Acetic Acid
- Nutrient Solution: Phosphoric Acid

Finished Water

- ND ClO₄⁻
- ND VOC

Startup-Time

- Circulate water during start-up
- Few weeks to stabilize the FBR
- 2-3 months to reach target effluent water quality

Design Considerations

- Real-Time analysis of influent and effluent water quality
- Careful attention to the design of system controls (SCADA)





GHD

Sunny Slope - Microvi

- Water Quality
 - 10 mg/L nitrate
 - Partially treated and blended
 - Target 8 mg/L nitrate
- Setup
 - Two reactor tanks each around 300 gpm
 - Only 1 tank fully operational
 - Followed by UF with ACH coagulant
- Maintenance
 - Bi/weekly tank scrub
 - Microvi rep monthly maintenance check





Conclusions

- Both physical and biological processes to treat perchlorate
- Each process has unique pros and cons
- Choice will depend on:
 - Influent water quality
 - Effluent water quality goals
 - Cost
 - Operating conditions





www.ghd.com



Sampling & Analytical Challenges for Common Constituents

Rick Zimmer Eurofins Eaton Analytical RickZimmer@eurofinsUS.com



SAMPLING & ANALYTICAL CHALLENGES

for common constituents

Rick Zimmer June 28, 2018

www.EurofinsUS.com/Eaton



PRESENTATION OUTLINE

- Common Terms & Concepts
- Coliforms
- Pathogens
- Volatile Organics
- 1,4-Dioxane
- Nitrosamines
- Conclusion



- ✓ Sampler Qualification
- Dedicated Tap Stations
- Container Checks

- Sample Segregation
- Sample Transport
- Cooler Cleanings
- ✓ Powder-Free/Nitrile Gloves ✓ Field QC samples
- Flush Time
- Container Handling

- ✓ Weather Management
- Chain of Custody

REPORTING LIMITS





Eaton Analytical
REPORTING LIMITS





QUALITY CONTROL











COLIFORMS & SAMPLING & ANALYSIS







Figure 1. Sample volume according to 40 CFR 141.21(f), Safe Drinking Water Act and EPA Manual for certification of Laboratories Analyzing Drinking Water (EPA 815-R-05-004, January 2005, 5th Edition)











Eaton Analytical

🛟 eurofins

PATHOGENS





LT2 ESWTR

2-log removal + 0.3 NTU turbidity standard Monitoring + Bin Classification Covered Storage Reservoirs Watershed Protection, Sanitary Surveys

- Gastrointestinal illness (sensitive populations)
- Found in Human & Animal fecal waste
- Resistant to conventional treatment



IESWTR—Interim Enhanced Surface Water Treatment Rule, UBT—upper bin technology; UBT includes riverbank (inbank) filtration, slow sand filtration, membranes, ultraviolet irradiation, chlorine dioxide, ozone, bag filter, and cartridge filter.

*Direct filtration facilities will require 0.5 log additional credit.

PATHOGENS SAMPLING & ANALYSIS





VOLATILE ORGANICS



Known or suspected Carcinogens in groundwater

Industrial solvents, Petroleum products, Fragrances, Paint, Lubricants, Cleaners

		MCL			MCL
REGULATION	COMPOUND	mg/L	REGULATION	COMPOUND	mg/L
	Benzene	0.005		cis-1,2-dichloroethylene	0.07
Phase I	Carbon tetrachloride	0.005		Ethylbenzene	0.7
	p-dichlorobenzene	0.075		Chlorobenzene	0.1
	Trichloroethylene	0.005		o-dichlorobenzene	0.6
1987	Vinyl chloride	0.002	Phase II	Styrene	0.1
	1,1,1-trichloroethane	0.2	1991	Tetrachloroethylene	0.005
	1,1-dichloroethylene	0.007		Toluene	1
	1,2-dichloroethane	0.005		Trans-1,2-Dichloroethyle	0.1
Phase V	Dichloromethane	0.005		Xylenes (Total)	10
1992	1,1,2-trichloroethane	0.005		1,2-dichloropropane	0.005
	1,2,4-trichlorobenzene	0.07			

🛟 eurofins



Collection & Analysis (EPA 524.2)

40 mIs in Amber Glass – No Headspace 2-Stage Preservation (HCI + $C_6H_8O_6$) ** 40 mIs + He \rightarrow Sorbent Trap Sorbent Trap + He \rightarrow GCMS Column



Challenges

Plastic, Rubber in collection mechanisms Residual or Microbial Activity Purge Water, Helium Gas, Sorbent Traps Air Contamination in Field or Lab Sample Cross Contamination



eurofins

1,4-DIOXANE





A probable carcinogen (B2) by all routes of exposure Highly soluble and mobile in groundwater

FOUND IN

Solvent Stabilizer for 1,1,1-TCA Degreasing, Deicing, Wetting Agent Cosmetics & Foods (Ethylene Oxide) PET plastic by-product Products with Suds - Sodium Laureth Sulfate "Ubiquitous Chemical"

REGULATIONS

WHO = 50 ug/L Risk Level = 0.35 ug/L NL = 1 ug/L UCMR3 = 0.07 ug/L



Collection & Analysis (EPA 522)** Challenges

125 mls in Amber Glass 2-Stage Preservation (NaHSO₃ + Na₂SO₄) 100 mls \rightarrow SPE + MeCl 2 mLs + IS \rightarrow GCMS Column



Plastic, Rubber in collection mechanisms **Residual or Microbial Activity** SPE Contamination Air Contamination in Lab Sample Cross Contamination ۰.

NITROSAMINES





Water soluble, mobile in soil Does not readily biodegrade, absorb or volatize

A human carcinogen, Hepatoxin, Liver Fibrosis

FOUND IN

REGULATIONS

UDMH Rocket Fuel by-product Smoked or Cured Foods, Meat, Beer Ethanalomines by-product Tobacco Smoke DBP from Disinfected Wastewater Anion Exchange Resins WHO = 50 ug/L PHG = 3 ug/L NL = 10 ug/L UCMR2 = 0.002 ug/L



Collection & Analysis (EPA 521) Challenges

1 L in Amber Glass

Single Preservation (Na₂S₂O₃)

500 mls → SPE/Coconut Charcoal + MeCl

 $1 \text{ mL} + \text{IS} \rightarrow \text{GCMS Column}$

Plastic, Rubber in collection mechanisms

SPE Contamination

Sample Cross Contamination

PTFE from Autosampler vials



🔅 eurofins







- 1. Proper Field Sampling is essential and necessary in producing a representative sample
- 2. Good Laboratory Practice has a meaningful impact in manner your samples are handled
- **3**. Quality Controls must be extensive and frequent
- 4. Test Methods are highly sensitive
- 5. Not all Results are the same





Rick Zimmer Senior Account Manager RickZimmer@EurofinsUS.com 949-716-7180



Best way to Addressing Reoccurring Bacteria Problems in a Water Supply Well

Michael Bodart General Pump Company mbodart@genpump.com



Best way to Addressing Reoccurring Bacteria Problems in a Water Supply Well 1 Seminar – June 28, 2018 Mike Bodart 12:45 pm



AWWA Standard

This document is an American Water Works Association (AWWA) standard. It is not a specification. AWWA standards describe minimum requirements and do not contain all of the engineering and administrative information normally contained in specifications. The AWWA standards usually contain options that must be evaluated by the user of the standard. Until each optional feature is specified by the user, the product or service is not fully defined. AWWA publication

of a standard does not constitute endorsement of any product or product type, nor does AWWA test, certify, or approve any product. The use of AWWA standards is entirely voluntary. This standard does not supersede or take precedence over or displace any applicable law, regulation, or codes of any governmental authority. AWWA standards are intended to represent a consensus of the water supply industry that the product described will provide satisfactory service. When AWWA revises or withdraws this standard, an official notice of action will be placed on the first page of the Official Notice section of Journal - American Water Works Association. The action becomes effective on the first day of the month following the month of Journal - American Water Works Association publication of the official notice.



Chlorination of Permanent Equipment and Material Used in Wells

All permanent equipment and material to be installed in the well shall be chlorinated just before installation. This shall be done by spraying exposed areas with a solution having a chlorine residual of not less than 200 mg/L.

<u>Chlorination of Well After Permanent Equipment is Installed</u> After permanent equipment is installed, the well shall be chlorinated by (1) treating the water in the well casing to provide a chlorine residual of no less than 50 mg/L; (2) circulating the chlorinated water within the well casing and pump column; and (3) pumping the well to waste to remove chlorinated water. Note: Circulation must be done with care, especially in older existing wells, as it may flush or loosen casings or screens.

4.5.1 Treating the water in the well casing. The water in the casing shall be treated with chlorine so that chlorine residual of no less than 50 mg/L is in the entire volume of water in the casing. This may be done by using granular calcium hypochlorite, calcium hypochlorite tablets, or sodium hypochlorite solution in the amounts shown in Table A.1. If calcium hypochlorite tablets are used, they shall be dribbled down the casing vent and at least 30 min shall pass to allow the tablets to fall through the water and dissolve. If sodium hypochlorite, or calcium hypochlorite dissolved on-site, is used, the solution must reach all parts of the well. To accomplish this, a tube shall be suspended through the well-casing vent, when possible, so that it reaches the bottom of the well. After it reaches the well bottom, it shall be withdrawn as the sodium hypochlorite solution is pumped through the tube. If not possible, the use of calcium hypochlorite tablets as described above may be appropriate. After the chlorine has been applied, the well shall be surged at least three times to improve the mixing and induce contact of the chlorinated water with the adjacent aquifer. The chlorine residual of this water shall be verified. The chlorinated water shall be allowed to rest in the casing for at least 12 hr. After the well has been chlorinated and allowed to rest for at least 12 hr, it shall be pumped to waste. The discharge water shall be tested periodically for chlorine residual. When no detectable chlorine residual is measured, the well shall continue to be pumped to waste for at least 15 min before proceeding with bacteriological sampling (Sec 5.1).

Circulating the chlorinated water: optional procedure. Following completion of the procedure described in Sec. 4.5.1, a pressure-tight connection shall be made at least 2 in. in diameter (but not larger than the discharge piping) from the pump discharge piping to the casing vent. The pump shall be operated against a throttled discharge valve to return a flow of several hundred gallons per minute down the well casing while the rest of the pumped water is discharged to waste. In low-producing wells, the rate of return need not exceed one-half the maximum rate of production of the well (see Figure A.2).

Caution: The discharge valve shall not be throttled to the extent that the pressure developed will damage equipment or pipe-restraining ties. This procedure will remove oil or other material that has accumulated on the water surface; care must be used to ensure that such material is recovered for proper waste disposal. The discharge water shall be tested periodically for chlorine residual. When no detectable chlorine residual is measured, the well shall continue to be pumped to waste for at least 15 min. The well shall then be sampled for bacteriological testing.





<u>Sandy material.</u> K = 50 ft/day dh/dl = 1 ft/1000 ft n_e = 0.22

1.



2. <u>Clayey material.</u> K = 0.00001 ft/day dh/dl = 1 ft/100 ft n_e = 0.02





Confined/Unconfined Aquifers



6.2







If I add 1 PPM of chlorine to this beaker of water with bacteria, stir and retest, the bacteria will test absent of coliform.

> RAIL P MNIY

CBR003298 [RF] © www.visualphotos.com



Rate of Reaction is critical

Many treatments assume you have stagnant water similar to a swimming pool, but in reality water is moving underground like a slow moving stream (measured as feet per day)





		https://secure.babc	ockl 🔎 - 🖴 d	Acc	ela Automatio	on®	🥖 Ele	ment Client	Connect	×			^ ★ ☆
🚕 📠 A	ccela (Irrigation calcula	ator 🧃 Babcock	Date D	Ouration 🔀 (Google Maps	s 📚 SWRO	CB 🧃 DRIN	C CCR ~ I		eCFR 🖂	CA SDWIS	»
	8	S B											
BABCOCK Laboratories, Inc.													
The Standard of Excellence for Over 100 Years													
					Optario Nunic	ical Utilities C	empany: Joli						
Documents Projects Search Methodology													
C 09	C 09/18/2017 14:05:09 PRŌMIUM Element ClientConnect												
Samples V A Results V A Flag Limits													
Received in last 30 days 60 days 90 days All Custom													
Row filter OntDW-no CC													
	WO # (🛊 Samples 🌲 Resul	ts Documents 🖕	Project Number 🚽		Sampled	ampled Date 🔶 Received Date		d Date 🔶	Due Date	• •	Status 👙	Status Date 🍦
	B710955	14 🛡	▼ 2 ▼	Special Mor	nitoring 09/12/2017			09/12/2017		09/15/2017		Completed	09/14/2017
	B710960	7 🗸	2 4	Special Mor	nitoring	09/12/2017		09/12/2017		09/15/2017		Completed	09/14/2017
	B710958	3 🔻	▲ 2 ▼	Special Mor	nitoring	09/12/2017		09/12/2017		09/21/2017		Completed	09/15/2017
	#	Sample	Analysis	Matrix	Anal	yte	Units	Rep Limit	Result	Qualifiers			
	01	Well 39 - Discharge	BT-HPC	Water	Heterotrophic	Plate Count	CFU/mL	1.0 830		B-01			
			BT-MMUG-P/A	Water	E. coli	_		1.1	Absent	_A			
	02	Well 39 - 750 ft bgs	BT-HPC	Water	Heterotrophic	n : Plate Count	CFU/mL	1.0	>5700	_PC B-01A			
			BT-MMUG-P/A	Water	E. coli			1.1	Absent	_A			
					Total Coliform			1.1	**PRESENT**	_P B-01A			
	03	Well 39 - 750 ft bgs	BT- xHPC dilution	Water	Heterotrophic Plate Count		CFU/mL	100	2900	B-01B			
	B7H2700	1 🔻	▼ ₹	Special Mor	nitoring	08/29/2017		08/29/2017		09/08/2017		Completed	09/05/2017

Groundwater and Wells, Third Edition



Figure 12.19. Engineered suction and pressurized packer assembly (General Pump Company of Los Angeles).

Startup & Testing

Startup of a pump with an inflatable packer requires a very strategic approach in order to avoid a catastrophic failure.

cienierail

SOMADAVSDY

YOUMANTOTELMB

HAMMERSDONTEEX EVERYTHING

Sorry, no Magic Pill !!

Questions?





How to Write the Perfect Well Redevelopment Specification

Michael Bodart General Pump Company mbodart@genpump.com



How to Write the Perfect Well Redevelopment Specification Seminar – June 28, 2018

Mike Bodart

1:15 p.m.



Learn How to Write the Perfect Water Well Redevelopment Specification that Can Be Used on All Wells.



HOLDOLPUTULISE

YOU THOUGHT YOU WOULD SAVE MONEY, BUT IN REALITY YOU SPENT WAY TOO MUCH, AND SCREWED UP YOUR MOST VALUABLE ASSET.

"All Redevelopment Tools and Processes" are a <u>waste of Public Funds</u> and are <u>extremely dangerous</u> to your most valued assets.


Unless You follow the Step-By-Step Process.



<u>Bid</u> – Wire Brush, AirBurst®, Inject Biocide, Inject Acid, Dual Air Swab, Develop Pump, Test Pump 24-Hour Test, Chlorination.

- \$200,000 Spent.
- Three (3) Months Down Time.
- Sanding Issues.
- Failed Coliform Test.
- Lost Well Efficiency.

Evaluation shows that the well only needed to be brushed with a biocide for \$10,000. Instead you spend another \$200,000 trying to get back what you had!!!.

Good Luck





Build your team of experts! Determine the issues that exist.



Build Your Team of Experts





What issues do you have?

Nitrates? TCE? Arsenic? Colored Water? Sanding? Air? Perchlorates? Iron? Manganese? Bacteria? Low Specific Capacity? Loss Capacity? Gravel Pumping? Oil in Water?



If you're not careful, you will hire the "Step Brothers" to work on your \$2,000,000 water well.





Interview / Visit / Question

- Interview P.M., Production, Application Engineer, Foreman
- Knowledge Local & Specific to Current and Future Projects
- Visit Shop, Capabilities, Experience
- Review Equipment / Capabilities
- Review Rehabilitation Processes
- Safety, Practices and Procedures



Your Consultant and Contractor Should Not Compete



Everyone Loses!



Example: Customer has lost capacity in their well and they <u>think</u> it is due to well plugging.





Review all of the historical records.



Deteriorating Well Performance

Well performance deteriorates through a combination of factors

Mineral Encrustation

Iron, manganese and calcium pH > 7.5 Physical plugging Silts, clay and fine sands (velocity)

Biological Fouling

Iron related bacteria (IRB)* Sulfate reducing bacteria (SRB) Slime forming bacteria

Corrosion

pH < 7.5, DO > 2 ppm $H_2S > 1 ppm, TDS > 1000 ppm$ CO2 > 50 ppm, Chloride > 300 ppm

Structural Change
Weak or failed casing
Age of structure
Aggressive or encrusting waters
Sand production
Change in operation, over pumping
Well liner – wrong design for application

Maintenance

Years between redevelopment Aggressive mechanical and/or chemical Coliform bacterial – excessive chlorine Run to fail





80% of the water production is from only 30 feet (10%) of the seven w











Definition of Terms

Static Water Level (feet bgs) Pumping Water level (feet bgs) Drawdown (feet)

Well Yield (Production – gpm)

Specific Capacity (gpm/foot of Drawdown)



Modified from Driscoll, 1986



Figure 6.10. Diagram showing parameters for the Thiem equation.



The five Actes Reside ney to used to view ext complete Piston Houses, scheme trut be profeted to complete, son, and rease a substant. Output: State of California Page 1 of 2 Page 1 of 2 Del Work Region (Bornow 12007) Use byok from New Completion Report New Exercision Region (Bornow 12007) Date Work Region (Bornow 12007) Use byok from New Completion Report New Exercision Region (Bornow 12007) Date Work Region (Bornow 12007) Use byok from New Completion Report New Exercision Region (Bornow 12007) Date Work Region (Bornow 12007) Use byok from New Completion Report New Exercision Region (Bornow 12007) Dete Work Region (Bornow 12007) Use byok from New Completion Region (Bornow 12007) Local Permit Agency (Do, San Bernether) Permit User 2012/2007 Detention Region (Bornow 12007) Detention Completion Completion (Dornow 12007) Permit Number 2020705043 Permit User 2012/2007 Permit Number 2020705043 Permit User 2012/2007 Orientation Region Region (Bornow 12007) Permit Deter 2012/2007 Orientation Region Region Region (Dornow 12007) Permit Deter 2012/2007 Description Permit Deter 2012/2007 Orientation Region Region (Dornow 12007) Description Permit New Present Region (Do	Sec. Sec. 1335 HOLT AVE. 10511 10511 10511 10511 10511 10511 10511 10511 10511 100 Sec. 100 Sec. 101 10511 102 Source of Sample 10511.db Beylik/ont40/run1/Elog.1 11me Circulation Si 10511.db 11me Circulation Si 1240 11me Circulation Si 0 11me Circulation Si 150 110 <th>PACIFIC</th>	PACIFIC
80 100 Send with Set 100 120 Send with Set Dealine	HE HE HE REAL OF A CONTRACT OF	ELECTRIC LOG
Lessings: Name Outside Stream Approximation Surface Disarder Type Makerial Technics Disarder Type The stream Set Surface Surface Set Surface Surf		Ľ

Sec. 1997

CAN'S SALE

14 Sec.

Graph of Results (GPM)





Sand Test Over Time



Step III

- Perform additional testing <u>before</u> you pull the pump.
- Change flow and/or conditions and monitor changes.
- Dynamic video logging
- Dynamic spinner logging
- Dye testing "Besst"
- Dynamic zone sampling.





Sand Content Measurement

The sample line shall be tapped as close to the pump head as possible to ensure that turbulence is high enough to keep the sand uniformly distributed in the water stream

Rossum Centrifugal Sand Tester



Sand Test at Various Flow Rates





















Evaluate the new data along with the historical records to determine the next step.





- Pull the pump.
- Video log.
- Static spinner?
- Zone sample?





• Determine the first process.



Sit down with Contractor's <u>experienced</u> engineer or geologist, the customer's staff and discuss the <u>options</u>.

The rehabilitation <u>you choose</u> needs to be based on <u>your</u> complete understanding of <u>risk</u>, benefits, and cost. It's <u>our</u> job to make sure we give you the information and a clear understanding of <u>risk</u>, benefits and cost.



- Maintenance Agreements
- Partnership with Consultants and Water Purveyors.
- Best safety record in the industry.
- Protect our reputation in the biggest market (Southern California) in the US
- Being #1 in this market requires a constant investment in talent and equipment.






I know more than everyone else. Your opinions or ideas are not needed.



When you evaluate your rehabilitation options, remember there is risk of doing nothing

- 1. Corrode your casing and screen
- 2. Well collapse
- 3. Sanding
- 4. Jetting
- 5. Higher pump cost
- 6. Lower yield



#1 – Build your team of experts.

- #2 **Evaluate** the well.
- #3 <u>Evaluate</u> options.
- #4 <u>Evaluate</u> the amount of risk with each option.
- **#5 <u>Evaluate</u> the cost.**



Develop my chemical treatment based on a water sample I sent to the lab. What about the 95% of data that is really needed?



Questions And Comments?





Well Construction and Rehabilitation Loan Program

Eshter Valle Rojas Water Replenishment District erojas@wrd.org

WELL CONSTRUCTION AND REHABILITATION LOAN PROGRAM

Esther Valle Rojas Sr. Water Resources Planner

June 28, 2018



WATER REPLENISHMENT DISTRICT OF SOUTHERN CALIFORNIA

Overview

➢ Background

What is the Well Construction and Rehabilitation Loan Program (Program)?

Program Policy & Application





Background



- Limitations by adjudicated pumping rights in the Central and West Coast Basin
- In 2016-17, 25% of allowable water rights were left unpumped
- Reasons why water rights were unpumped:
 - Declining Well Capacity
 - Aging/Failing Wells
 - Clogged Perforations
 - Collapsed Casing
 - Sand Intrusion
 - Poor Water Quality



Background

- > District programs that help groundwater producers remedy their well problems:
 - Safe Drinking Water Program: promotes cleanup of groundwater resources
 - Removal of VOCs by offering financial assistance for the design, equipment and installation of wellhead treatment facilities at existing production wells
 - Provides zero-interest loans for secondary constituents for a specific production well
 - Well Profiling: evaluates the flow and water quality across the well screens
 - NEW! Well Construction and Rehabilitation Loan Program



About the Program

- WRD Board of Directors recently approved the development of the Program
- The Program can improve a producer's ability to optimize their groundwater rights
- > The Program's purpose is to assist with:
 - Drilling and installing of new wells
 - Repairing existing wells
 - Rehabilitating existing wells





➢ Eligibility

- Must be an entity within the WRD Service Area
- Must be a Party to the Central Basin Judgment or the West Coast Basin Judgment
- Applicant must demonstrate that the new well construction or well rehabilitation <u>will increase their annual extraction beyond</u> their most recent 5-year extraction average by at least 10%



- The District will provide 10 year, no interest loans for well construction and well rehabilitation projects. Loan may cover:
 - Design and construction
 - Well pump, meters, piping and connections to distribution system, if authorized by WRD Board
- Groundwater Producer will be the lead agency responsible for managing all aspects of the project. WRD can provide assistance if requested with expenses added to the loan amount.
- The District will be an Agent of the groundwater producer for the duration of the project, authorized to participate and comment on all aspects.
 - The District must agree with the selection of any hired consultant/contractor





- Rehabilitation Projects: District will consider rehabilitation projects that are unable to produce water due to:
 - Collapsed or corroded casing or screen
 - Clogged perforations
 - Sediment infilling
 - Other reasons will be considered for a well losing partial or full capacity

- > The groundwater producer will be the owner of the new well
- The groundwater producer is responsible for the full Program Loan repayment whether or not the completed well produces the anticipated groundwater yield
- Approved projects must commence within 90 days of approval and be completed within 18 months of approval
- WRD will not pay the consultant/contractor directly. WRD will reimburse the groundwater producer for WRD-approved invoices within 60 days of payment



General Program Requirements & Conditions



- Groundwater producers may not request funds to construct new wells if they have existing wells that are inactive due to water quality problems. They will be referred to the Safe Drinking Water Program instead.
- CEQA: activities funded under the Program regardless of the funding source must be in CEQA compliance. WRD may assist with CEQA compliance
- Funding limits shall be subject to the Program budget established by the WRD Board of Directors



General Program Requirements & Conditions

- Contractual Agreements
 - A completed application and resolution adopted by the applicant's governing body authorizing the entity to apply for funding is required
- Repayment of Loan: an initial payment is due within one month after project completion, then quarterly thereafter.
- Audit: WRD retains the right to audit the performance of the project to ensure the project increased the applicant's annual extraction beyond their most recent 5-year extraction average by at least 10%





Program Application

Prioritization

- Application date: "first applied, first considered"
- Projects located in a Disadvantaged Community: defined as a community with an annual Median Household Income (MHI) that is 80% of the statewide MHI
- Type of agency: Not-for-profit public or government agencies, mutual water companies, or private citizen who are rights holders (i.e. cities, county, mutual water companies, individuals) receive higher priority over for-profit entities



Program Application

> Applications are available at <u>www.wrd.org</u>

- > All sections must be completed
- > Submit via mail or email to:

Water Replenishment District of Southern California Attn: Ted Johnson, Chief Hydrogeologist 4040 Paramount Blvd Lakewood, CA 90712 tjohnson@wrd.org





Thank you!

Questions or inquiries, contact: Esther Valle Rojas <u>erojas@wrd.org</u>

> <u>www.wrd.org</u> (562)-921-5521



For more information visit www.wrd.org

NRD.